

NOTES:

1. CONTRACTOR SHALL BE RESPONSIBLE FOR PROPER SLOPE AND CONSTRUCTION OF CONNECTING PIPE.
2. INVERT OF CONNECTING PIPE SHALL MATCH CROWN OF DISTRICT SEWER UNLESS OTHERWISE DIRECTED BY THE DISTRICT.
3. MANHOLE PIPE CONNECTIONS SHALL BE A FLEXIBLE WATER-TIGHT BOOT PER ASTM C923 AND BE FACTORY INSTALLED UNLESS OTHERWISE APPROVED BY THE DISTRICT (KOR-N-SEAL, OR APPROVED EQUAL).

