



NOTES:

1. CONTRACTOR MUST NOTIFY THE DISTRICT 48 HOURS BEFORE WORK BEGINS.
2. CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTION OF EXISTING SEWER AND OTHER UTILITIES, PROPER BACKFILLING, COMPACTING, AND SURFACE RESTORATION.
3. ABANDONMENT MUST BE INSPECTED AND APPROVED BY THE DISTRICT PRIOR TO ENCASEMENT AND BACKFILLING.
4. THE DISTRICT'S SEWER PIPE WALL SHALL BE CLEANED TO A WIDTH OF 12 INCHES AROUND THE PLUG LOCATION.
5. SIX INCHES OF CONCRETE SHALL BE PLACED OVER THE PLUG AND TO A WIDTH OF 12 INCHES AROUND THE PLUG OR AS DIRECTED BY THE DISTRICT. ENCASEMENT MUST BE SUFFICIENTLY SIZED TO PREVENT DISPLACEMENT OF PLUG DURING SEWER CLEANING AND OTHER MAINTENANCE ACTIVITIES.
6. CONCRETE SHALL BE TYPE I/II PORTLAND CEMENT PER ASTM C150 WITH A MINIMUM COMPRESSIVE STRENGTH OF 4000 PSI PER ASTM C39. NO ADDITIVES SHALL BE PERMITTED WITHOUT PRIOR APPROVAL BY THE DISTRICT.
7. CONTRACTOR SHALL MEASURE THE DISTANCE FROM THE NEAREST MANHOLE TO THE CENTER OF THE PLUG AND FURNISH MEASUREMENTS TO THE DISTRICT.
8. SEE ND-06 FOR ACCEPTANCE TESTING, FINAL COMPLETION, AND WARRANTY REQUIREMENTS.



NORTH DAVIS SEWER DISTRICT

ND-19 Standard Service Connection Abandonment